



SET BASE ON BRICK OR FLAT STONE AFTER BACKFILLING PIPE
 ⚠

PLAN

COVER-CLOW F-2493 "STAY-PUT" TYPE (OR CITY APPROVED EQUAL) ⚠

24" x 24" x 4" CONCRETE APRON IN NON-PAVED AREAS.

⚠ ⚠ CONCRETE COLLAR PER D-311

TWO PIECE SCREW TYPE VALVE BOX - CLOW TYPE F-2454 (OR CITY APPROVED EQUAL) ⚠

BRICK OR FLAT STONE

GATE VALVE

① 2" WIDE CONCRETE* THRUST BLOCK SET ON UNDISTURBED EARTH PLACE PLASTIC BETWEEN BLOCK AND PIPE VALVES AND FITTINGS

⚠ GATE VALVE OR BUTTERFLY VALVE

SECTION

*PRE-MIXED CONCRETE BAGS MAY BE USED WITH CITY ENGINEER APPROVAL.

NOTE

① MEG-A-LUG WEDGE ACTION JOIST RESTRAINT, SERIES - 1100 FOR CAST IRON OR DUCTILE, SERIES - 1100 PV FOR CAST IRON SIZE PVC (TYPICAL)

REV.	DATE
⚠	1/20/99
⚠	11/19/04
⚠	12/02/05

CONSTRUCTION STANDARDS

VALVE INSTALLATION

STANDARD No. D-203 SHEET 1 OF 1

CITY OF AZTEC
 PUBLIC WORKS DEPARTMENT