



NOTES

- 1) ENCASEMENT IS REQUIRED WHERE THE VERTICAL SEPARATION BETWEEN A WATER LINE AND A V.C.P. SEWER LINE DOES NOT EXCEED 24" AT A CROSSING. ENCASEMENT IS TO EXTEND A MINIMUM OF 10' EACH DIRECTION ALONG THE SEWER LINE FROM THE POINT OF CROSSING.
- 2) ENCASEMENT IS NOT REQUIRED IF DUCTILE IRON PIPE OR PVC IS USED FOR SEWER LINE A MINIMUM OF 10' EACH DIRECTION FROM CROSSING. IF WATER MAIN CROSSES UNDER SEWER MAIN, THE SEWER MAIN MUST BE ENCASED, AND WATER MAIN SHALL BE DUCTILE IRON PIPE.

REV.	DATE
1	12/15/94

**CONSTRUCTION
STANDARDS**

**SEWER LINE
ENCASEMENT**

STANDARD No. D-409 SHEET 1 OF 1

**CITY OF
AZTEC
PUBLIC WORKS
DEPARTMENT**