

NOTE:

IF GATE VALVE IS APPROXIMATELY 6 FEET OR LESS FROM THE MAIN TEE, THEN PLUG IMMEDIATELY AFTER GATE VALVE. OTHERWISE, PLUG AFTER MAIN LINE TEE.

	TYPICAL FIRE HYDRANT ABANDONMENT	STANDARD NO. W-20 SHEET 2 OF 3
City of Aztec Public Works Department	CONSTRUCTION STANDARDS	APP'D <u>R. Salcido</u> DATE <u>Oct. 11, 2023</u>