



CITY OF AZTEC

ADDENDUM # 1

Invitation to Bid ITB # 2025-863

WILLIAMS ARROYO BANK REPAIR PHASE 1

ADDENDUM DATE: February 21, 2025

BID DUE DATE/ TIME: February 26, 2025, 3:00 PM

This addendum includes the following:
Clarifications, Question and Answer:

1. Paving Notes, Item 1: Areas where city has issued prior authorization to remove asphalt, curb and gutter will be repaired according to unit costs included in bid. Damaged or removed areas without prior authorization are to be repaired at contractor's own expense.
2. Construction Testing Notes, Item 2: No redundancy testing required.
3. An allowance of \$5000 will be added to the contract for construction testing.
4. Q: "Is achieving 95% compaction mandatory, or would a lower compaction level be acceptable in the area with running water where it may not be easily attainable?"
 - a. A: See Geotechnical report, proof compaction under observation of geotechnical engineer is allowable under certain conditions.

For further information contact:
Vanessa Tanner, Project Procurement Specialist, CPO
Phone: 505-334-7652
email: vtanner@aztecnm.gov
